

MECHANICAL SPECIFICATIONS

- A. THE WORK HEREIN INCLUDES PROVIDING THE INDICATED SYSTEMS AND PROVIDING NEW MATERIALS, FITTINGS AND ACCESSORIES NECESSARY FOR COMPLETE FUNCTIONING SYSTEMS. THE WORK ALSO INCLUDES FINAL CONNECTIONS TO ALL EQUIPMENT PROVIDED BY THIS CONTRACTOR AS WELL AS ALL EQUIPMENT PROVIDED BY OTHERS AND THE CONTRACTOR SHALL ACCORDANCE WITH THE LATEST RULES, REGULATIONS AND CODES OF THE STATE OF PENNSYLVANIA, AS WELL AS LOCAL AND/OR ORDINANCE CODES. WORK IS SUBJECT TO INSPECTION BY ANY AND ALL CRRIFIED PROFESSIONALS PERTINENT TO THE COMPLETION OF THIS PROJECT.
- B. THE INTENT OF THE DRAWINGS IS TO INDICATE THE GENERAL SCHEME OF WORK REQUIRED FOR THE PROJECT. THESE DRAWINGS ARE **DIAGRAMMATIC IN NATURE** AND THEREFORE SHOW GENERAL LOCATION, TYPE, RANGES AND EQUIPMENT REQUIRED. THE DRAWINGS SHALL NOT BE SCALED FOR EXACT MEASUREMENTS. REFER TO MANUFACTURERS STANDARD ROUGH-IN DRAWINGS FOR EXACT CONNECTION LOCATIONS. COORDINATE CAREFULLY WITH EXISTING DUCT, EQUIPMENT AND STRUCTURE.
- C. ALL WORK IS TO BE COORDINATED WITH THE WORK OF ALL OTHER TRADES AND WITH EQUIPMENT FURNISHED BY OTHERS.
- D. CONTRACTOR TO FIELD VERIFY ALL EXISTING CONDITIONS PRIOR TO BID. NO ERRORS WILL BE ALLOWED FOR CONTRACTOR FAILURE TO BECOME FAMILIAR WITH ALL EXISTING CONDITIONS AND THE LOCATION OF ALL EXISTING AND DISCHARGE/ACCESS HUBS FOR RESOLUTION.
- E. SUBMIT SHOP DRAWINGS FOR ALL EQUIPMENT TO ENGINEER FOR APPROVAL PRIOR TO COMMENCING WORK.
- F. ALL NEW EQUIPMENT, MATERIALS AND INSTALLATION ARE TO BE WARRANTED FROM ONE YEAR TO BE FREE OF DEFECT.
- G. ALL INSULATION SHALL MEET TEMPERATURE AND SMOKE RATINGS AS REQUIRED BY NFPA FOR THE INTENDED USE.
- H. COORDINATE ALL EQUIPMENT TO ALLOW FOR SERVICE ACCESS. DO NOT ALLOW OVERTOPPING, CONDUITS OR OTHER MATERIALS TO BE INSTALLED THAT WOULD PREVENT ACCESS. PROVIDE ACCESS PANELS WHERE WALLS AND/OR CEILING PREVENT ACCESS TO EQUIPMENT.
- I. INSTALL ALL EQUIPMENT PER MANUFACTURERS INSTRUCTIONS.
- J. MECHANICAL CONTRACTORS TO INSPECT ALL NEW DUCTWORK FOR AIR LEAKAGE AND PATCH/REPAIR DUCTWORK AS REQUIRED WITH ACCEPTABLE SEALANT. DUCTWORK SEALING SHALL BE TO THE SATISFACTION OF THE ARCHITECT/ENGINEER.

DUCTWORK

- A. PERFORM WORK IN ACCORDANCE WITH SMACNA - HVAC DUCT CONSTRUCTION STANDARDS - METAL AND FLEXIBLE, UNLESS MORE STRINGENT REQUIREMENTS ARE NOTED IN LOCAL CODES.
- B. UNLESS NOTED OTHERWISE, ASTM A555 AND ASTM A557 GALVANIZED STEEL SHEET LOCK-FORMING QUALITY, HAVING 600 ZINC COATING OF IN CONFORMANCE WITH ASTM A90.
- C. FABRICATE AND SUPPORT IN ACCORDANCE WITH SMACNA HVAC DUCT CONSTRUCTION STANDARDS - METAL AND FLEXIBLE, UNLESS MORE STRINGENT REQUIREMENTS ARE NOTED IN LOCAL CODES.
- D. INSTALL AND SEAL DUCTS IN ACCORDANCE WITH SMACNA HVAC DUCT CONSTRUCTION STANDARDS - METAL AND FLEXIBLE, UNLESS MORE STRINGENT REQUIREMENTS ARE NOTED IN LOCAL CODES.
- E. SUPPORT DUCTWORK IN ACCORDANCE WITH SMACNA HVAC DUCT CONSTRUCTION STANDARDS - METAL AND FLEXIBLE, CHAPTER 4; HANGERS AND DUCT HANGERS SHALL NOT ATTACH TO BOTTOM CHORD OF STEEL JOIST OR METAL ROOF DECKING, ATTACH TO TOP CHORD OF STEEL JOIST.
- F. CONNECT DIFFUSERS OR LIGHT TRAFFER BOOTS TO LOW PRESSURE DUCTS DIRECTLY OR WITH 5 FEET MAXIMUM LENGTH OF FLEXIBLE DUCT HELD IN PLACE WITH STRAP OR CLAMP.
- G. PROTECT DUCTWORK DURING CONSTRUCTION. PROVIDE TEMPORARY CLOSURES OF METAL OR FLEXIBLE DUCTWORK TO PREVENT CONSTRUCTION DUST FROM ENTERING DUCTWORK SYSTEM.
- H. INSULATION: ALL SUPPLY AND RETURN DUCTWORK SHALL HAVE 1-1/2" DUCTWRAP. PROVIDE 1" DUCTWRAP INSULATION ON FIRST 10 FEET OF EXHAUST DUCTWORK FROM ROOF PENETRATION.

TESTING, ADJUSTING & BALANCING

- A. WORK INCLUDES:
1. TESTING, ADJUSTMENT, AND BALANCING OF NEW AIR SYSTEMS.
 2. MEASUREMENT OF FINAL OPERATING CONDITION OF HVAC SYSTEMS.
 3. SERVICES PROVIDED BY AN INDEPENDENT, CERTIFIED TESTING AND BALANCING AGENCY.
 4. REPORT: TOTAL SYSTEM BALANCE IN ACCORDANCE WITH ASAC NATIONAL STANDARDS FOR FIELD MEASUREMENT AND INSTRUMENTATION, TOTAL SYSTEM BALANCE OR NEBB PROCEDURAL STANDARDS FOR TESTING, BALANCING AND ADJUSTING OF ENVIRONMENTAL SYSTEMS.
 5. SUBMIT COPIES OF TAB REPORT TO ENGINEER FOR APPROVAL PRIOR TO FINAL INSPECTION. PROVIDE COPY OF FINAL, APPROVED TAB REPORT TO CODE INSPECTOR AT FINAL INSPECTION.

AUTOMATIC TEMPERATURE CONTROLS

- 1.1. EXHAUST FAN (EF-1) SHALL BE INDEXED ON AT EITHER LAB HOOD, EXHAUST FAN SWITCHES SHALL BE WIRED IN PARALLEL TO START FAN AT EITHER HOOD.
- 1.2. ALLOW LEAKAGE, MOTORIZED DAMPER SHALL BE PROVIDED IN EXHAUST FAN CURB TO CLOSE WHEN EXHAUST FAN IS OFF.
- 2.1. MAKE-UP AIR UNIT (MAU-1) SHALL BE INTERLOCKED TO RUN WHENEVER EXHAUST FAN (EF-1) IS OPERATING.
- 2.2. A DISCHARGE AIR THERMOSTAT SHALL BE INSTALLED IN THE SUPPLY AIR DUCTWORK FROM THE UNIT.
- 2.3. OUTDOOR AIR THERMOSTATS SHALL INDEX THE UNIT TO COOLING WHEN THE OUTDOOR AIR TEMPERATURE RISES ABOVE THE FIELD ADJUSTABLE.
- 2.4. THE OUTDOOR THERMOSTAT SHALL INDEX THE UNIT TO HEATING WHEN THE OUTDOOR AIR TEMPERATURE DROPS BELOW 65° F (ADJUSTABLE).
- 2.5. THE DISCHARGE THERMOSTAT SHALL CYCLE THE COOLING TO MAINTAIN A DISCHARGE AIR TEMPERATURE OF 72 DEGREES F (ADJUSTABLE).
- 2.6. THE DISCHARGE THERMOSTAT SHALL CYCLE THE HEATING TO MAINTAIN A DISCHARGE AIR TEMPERATURE OF 65 DEGREES F (ADJUSTABLE).
- 2.7. ALLOW LEAKAGE, MOTORIZED OUTDOOR AIR DAMPER SHALL BE PROVIDED IN OUTDOOR AIR INTAKE TO CLOSE WHEN THE MAKE-UP AIR UNIT IS OFF.

ROOF MOUNTED EXHAUST FAN SCHEDULE

REF.	MANUFACTURER/MODEL	CFM	ESP IN. WG	FAN RPM	DRIVE	AREA SERVED	HP MOTOR	REMARKS
EF-1	GREENHECK / VECTOR 'H' SIDE 'W' 8" NOZZLE	1,030	0.80	3,175	BELT	CHEMISTRY / PREP	1 HP 208V/3PH/60HZ	INTERLOCK TO RUN FROM EITHER LAB HOOD

NOTES:

1. ACID RESISTANT EPOXY COATING FOR ALL PARTS AND ACCESSORIES (BACKDRAFT DAMPER, ETC.) EXPOSED TO AIRFLOW.
2. WITH HIGH FLOW DISCHARGE NOZZLE, ROOF CURB, 8"-PASS FLEXIM AND MOTORIZED ISOLATION DAMPER.


MAKE-UP AIR UNIT SCHEDULE

TAG	REF.IG.	TOTAL CMH	OA CMH	COOLING CAPACITY			HEATING CAPACITY			EFF.	FAN MOTOR DATA			ELECTRICAL DATA						
				TOTAL MBH	SENSIBLE MBH	EB3 °F	EB4 °F	341 °F	SEER		GAS INPUT	NET OUTPUT	0	80%	HP	RPM	TYPE	Volts	Phase	MCA
AHU-1	R-410A	1,290	1,030	621	492	83	70	60	13	100 MBH	80 MBH	0	80% <td>1/2</td> <td>1090</td> <td>TC</td> <td>208</td> <td>3</td> <td>25.1</td> <td>YORK / RH00T10P2AA2A</td>	1/2	1090	TC	208	3	25.1	YORK / RH00T10P2AA2A


NOTE: PROVIDE DISCHARGE AIR SENSOR, INTERLOCK UNIT TO RUN WITH EF-1.

DIFFUSER GRILLE & REGISTER SCHEDULE

TAG	AIR SERVICE	FACE TYPE	FACE SIZE	NECK SIZE	JOINT	FRAME	DAMPER	MANUFACTURER / MODEL	NOTES
G-1	RETURN	BAR	25-3/4" X 13-3/4"	24X72	WALL	PLASTER	O&B	PRICE / 24" X 12" S101 F D A B12	BLADES SHALL BE ANGLED UP
R-1	SUPPLY	BAR	17-3/4" X 11-3/4"	16X10	WALL	PLASTER	O&B	PRICE / 16" X 10" S200 F S D A B12	
R-2	SUPPLY	BAR	23-3/4" X 11-3/4"	22X10	WALL	PLASTER	O&B	PRICE / 22" X 10" S200 F S D A B12	




3 PARTIAL ROOF PLAN
SCALE: 1/8" = 1'




2 FIRST FLOOR HVAC PLAN
SCALE: 1/8" = 1'

MECHANICAL LEGEND

- SUPPLY DIFFUSER
- RETURN GRILLE
- EXHAUST GRILLE
- VOLUME DAMPER
- FLEX DUCT
- DUCT TAKE OFF
- FLEXIBLE CONNECTION
- SIDE WALL RESISTER
- THERMOSTAT
- SMOKE DETECTOR
- MOTORIZED DAMPER
- FIRE DAMPER
- ACCESS PANEL
- VELOCITY PROBE
- POINT OF NEW CONNECTION




4 FIRE DAMPER DETAIL
SCALE: NONE



1 KEY PLAN
SCALE: NONE

PBCI Engineering
a division of Penn Building Company, Inc.
2746 West College Avenue
State College, PA 16801
phone: 814.234.7366
fax: 814.234.7040
PBCI No.: E33004
© 2019 Penn Building Company, Inc.



PROGRESS DATES

- | | |
|--------------------|----------|
| DESIGN REVIEW SET | 02/18/13 |
| CODE & BIDDING SET | 02/25/13 |
| CODE RESUBMISSION | 05/21/13 |
| CODE RESUBMISSION | 06/06/13 |

ST. JOSEPH'S CATHOLIC ACADEMY
901 Boalsburg Pike
Boalsburg, PA 16827

HVAC PLANS & SPECIFICATIONS

H1